

**300 P-340BBLDG-001****340-B-BLDG (inactive)**

340 BUILDING

Emission Unit ID: 424

**Abatement Technology (state only enforceable)**

Applicable Requirements: ALARACT

ALARACT [WAC 246-247-040(4)]

BARCT [WAC 246-247-040(3)]

Zone or Area	Description of Abatement Technology [WAC 246-247-010(4)] [WAC 246-247-040(4)]	Required Number of Units [WAC 246-247-010(4)] [WAC 246-247-060(5)]	Additional Description/Conditions [WAC 246-247-010] [WAC 246-247-040(4)] [WAC 246-247-060(5)]
	Fan	1	Fan operates intermittently
	HEPA	1	2 in parallel (minimum of 1 active flow path providing 1 stage of HEPA filtration)
	Prefilter	1	In parallel (minimum of 1 active flow path providing 1 stage of HEPA filtration)

**Monitoring Requirements (state and federally enforceable)**

Federal and State Regulatory Requirements	Monitoring and Testing Procedure [WAC 246-247-040(5)] [WAC 173-401-615(1)]	Radionuclides Requiring Measurement [WAC 173-401-615(1)]	Sampling Frequency [WAC 246-247-075(1)] [WAC 173-401-615(1)]
40 CFR 61.93[b][4][i] & Appendix B, Method 114(3) WAC 246-247-075[3]		monitoring not currently performed	4 weeks/year (inactive)

**Sampling Requirements** [WAC 246-247-075(5), WAC 173-401-615(1)]:

Record Sample